



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**

TC-12273

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

ULR- TC-1127324000003420F

Report No - KWA/QA/R/06/3420/J/28/8235	Date : 21/06/2024
Customer Name and Address	1. Date of receipt : 20/06/2024
Sree Narayana English Medium School Chekkikulam (NON-DOMESTIC PURPOSE)	2. Sampling Provided by : Customer(QUA_144107)
	3. Sample Code : 2393
	4. Sample : Drinking Water
	5. Source of Sample : Bore Well
	6. Sample quantity : 2 litre
	7. Test performing dates
	From : 20/06/2024 To : 21/06/2024

SI NO	Characteristic	Test Method	Requirement as per IS 10500-2012		Result
			Acceptable Limit	Permissible Limit in the absence of alternate source	
1	Taste	IS 3025 (Part 8)-2023 Second Revision	Agreeable	Agreeable	-
2	Colour ,HAZEN Units, Max	IS 3025 (part 04) -2021	5	15	-
3	Odour	IS 3025 (part 5) -2018	Agreeable	Agreeable	-
4	Turbidity ,NTU, Max	IS 3025(part 10)-2023	1	5	0.24
5	pH	IS 3025 (part 11) - 2022	6.5 to 8.5	No relaxation	6.37
6	Total Alkalinity (as CaCO ₃) , mg/l, Max	IS 3025 (part 23) -2023	200	600	-
7	Total Dissolved Solids (TDS), mg/l, Max	IS 3025 (part 16) -2023 Second Revision	500	2000	-
8	Total Hardness (as CaCO ₃) ,mg/l, Max	IS 3025 (part 21) -2009 Second Revision	200	600	52.30
9	Calcium (as Ca) ,mg/l, Max	IS 3025 (part 40) -1991 (Reaffirmed 2019)Amendment No 1 2004	75	200	-
10	Magnesium (as Mg) , mg/l, Max	IS 3025 (part 46) -2023	30	100	-
11	Chloride(as Cl) , mg/l, Max	IS3025(part 32)-1988 (Reaffirmed 2019)	250	1000	6.30
12	Electrical Conductivity at 25°C, micro mhos/cm	IS 3025 (part 14) -2013 (Reaffirmed 2019)			149.00
13	Residual Free Chlorine , mg/l, Min	IS 3025 (part 26) -2021	0.2	1	-
14	Sulphate (asSO ₄) , mg/l, Max	IS 3025 (part 24/sec 1) :2022	200	400	-

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

Rekha V K

Quality Manager

SR SANITARY CHEMIST LAB
 QUALITY CONTROL DISTRICT LAB
 KERALA WATER AUTHORITY
 KANNUR-1
 Rev No: 002
 Rev Date: 29.07.2023
 Page 1 of 3

* End Of Report*

KWA/QC/KNR/R/17

Issue No: 03

Issue Date: 29.07.2023



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**



TC-12273

Tele phone No : 0497 2704380
email : kwaqlabkannur@gmail.com

ULR- TC-1127324000003420F

Report No - KWA/QA/R/06/3420/J/28/8235	Date : 21/06/2024
Customer Name and Address	1. Date of receipt : 20/06/2024
Sree Narayana English Medium School Chekkikulam (NON-DOMESTIC PURPOSE)	2. Sampling Provided by : Customer(QUA_144107)
	3. Sample Code : 2393
	4. Sample : Drinking Water
	5. Source of Sample : Bore Well
	6. Sample quantity : 2 litre
	7. Test performing dates
	From : 20/06/2024 To : 21/06/2024

SI NO	Characteristic	Test Method	Requirement as per IS 10500-2012		Result
			Acceptable Limit	Permissible Limit in the absence of alternate source	
1	Taste	IS 3025 (Part 8)-2023 Second Revision	Agreeable	Agreeable	-
2	Colour ,HAZEN Units, Max	IS 3025 (part 04) -2021	5	15	-
3	Odour	IS 3025 (part 5) -2018	Agreeable	Agreeable	-
4	Turbidity ,NTU, Max	IS 3025(part 10)-2023	1	5	0.24
5	pH	IS 3025 (part 11) - 2022	6.5 to 8.5	No relaxation	6.37
6	Total Alkalinity (as CaCO ₃) , mg/l, Max	IS 3025 (part 23) -2023	200	600	-
7	Total Dissolved Solids (TDS), mg/l, Max	IS 3025 (part 16) -2023 Second Revision	500	2000	-
8	Total Hardness (as CaCO ₃) ,mg/l, Max	IS 3025 (part 21) -2009 Second Revision	200	600	52.30
9	Calcium (as Ca) ,mg/l, Max	IS 3025 (part 40) -1991 (Reaffirmed 2019)Amendment No 1 2004	75	200	-
10	Magnesium (as Mg) , mg/l, Max	IS 3025 (part 46) -2023	30	100	-
11	Chloride(as Cl) , mg/l, Max	IS3025(part 32)-1988 (Reaffirmed 2019)	250	1000	6.30
12	Electrical Conductivity at 25°C, micro mhos/cm	IS 3025 (part 14) -2013 (Reaffirmed 2019)			149.00
13	Residual Free Chlorine , mg/l, Min	IS 3025 (part 26) -2021	0.2	1	-
14	Sulphate (asSO ₄) , mg/l, Max	IS 3025 (part 24/sec 1) :2022	200	400	-

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

Rekha V K

Quality Manager

*SR. SANITARY CHEMIST LAB
QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY
KANNUR-1
Rev No: 002 Rev Date: 29.07.2023
Page 1 of 3

KWA/QC/KNR/R/17

Issue No: 03

Issue Date : 29.07.2023

* End Of Report*



**KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT**



TC-12273

ULR-TC-1127324000003420F

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

Report No - KWA/QA/R/06/3420/J/28/8235		Date : 21/06/2024
Customer Name and Address Sree Narayana English Medium School Chekkikulam (NON-DOMESTIC PURPOSE)	1. Date of receipt	: 20/06/2024
	2. Sampling Provided by	: Customer(QUA_144107)
	3. Sample Code	: 2393
	4. Sample	: Drinking Water
	5. Source of Sample	: Bore Well
	6. Sample quantity	: 2 litre
	7. Test performing dates	From : 20/06/2024 To : 21/06/2024

Sl. No	Characteristic	Test Method	Requirement as per IS 10500-2012		Result
			Acceptable Limit	Permissible Limit in the absence of alternate source	
15	Fluoride (as F), mg/l, Max	APHA24th Edition 4500-F-D. SPADNS Method	1	1.5	-
16	Iron (as Fe), mg/l, Max	IS 3025 (part 53) -2024 Second Edition	1	No relaxation	0.01
17	Nitrate (as NO ₃), mg/l, Max	APHA24th Edition 4500 NO ₃ -B(UV Screening Method)	45	No relaxation	0.24
18	Ammonia (as NH ₃ - N), mg/l, Max	IS 3025 (Part 34)-1988 (Reaffirmed 2019)	0.5	No relaxation	-

Sl. No	Characteristic	Test Method	Result
1	Phosphorous (as P) , mg/l]	IS 3025 (part 31/sec 1): 2022	-
2	Dissolved Oxygen , mg/l	IS 3025(Part 38)-1989(Reaffirmed 2019)	-
3	Total Suspended Solids ,mg/l	IS 3025(Part17)-Second revision 2022	-
4	Oil and Greese, mg/l	IS 3025 (Part 39)- 2021	-
5	Bio chemical Oxygen Demand, mg/l	IS 3025(Part 44)-2023	-
6	Chemical Oxygen Demand , mg/l	IS 3025 (Part 58)-2022	-
7	Acidity, mg/l	IS 3025 (part 22) -1986 (Reaffirmed 2019)	-

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By

Rekha V K

Quality Manager

SR. SANITARY CHEMIST
Rev No: 002 Rev Date: 29.07.2023
QUALITY CONTROL LAB
KERALA WATER AUTHORITY
KANNUR
Page 2 of 3

KWA/QC/KNR/R/17

Issue No: 03

Issue Date: 29.07.2023



KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT


Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

Report No - KWA/QA/R/06/3420/J/50/131A				Date : 21/06/2024			
Customer Name and Address		1. Date of receipt		: 20/06/2024			
Sree Narayana English Medium School Chekkikulam (NON-DOMESTIC PURPOSE)		2. Sampling Provided by		: Customer(QUA_144107)			
		3. Sample Code		: 2393			
		4. Sample		: Drinking Water			
		5. Source of Sample		: Bore Well			
		6. Sample quantity		: 100 ml			
		7. Test performing dates		From: 20/06/2024		To: 21/06/2024	
		Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	37		
2	E.Coli	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil		

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

Authorised By



Bacteriologist

* End Of Report*

KWA/QC/KNR/R/17

Issue No: 02

Issue Date: 01.06.2021

BACTERIOLOGIST
KWA QC CONTROL DISTRICT LAB KANNUR
KERALA WATER AUTHORITY
KANNUR 070 012
Page 3 of 3

Ref. No. 2/2024
25.6.2024

Primary Health Centre
Kuttiyattoor

Date: 25.6.2024

SANITARY FITNESS CERTIFICATE

As per the Govt. Notification No. 1054 / 43 / 79 HD dated 27th June 1979 I.....K. P. SADANANDAN.....health Inspector P.H.C. Kuttiyattoor and Health Officer of Kuttiyattoor Grama panchayath area do hereby certify that the site in R. S. No:..... Building No: XII / A1 ABCD Kuttiyattoor Grama Panchayath proposed for SREE NARAYANA ENGLISH MEDIUM SCHOOL CHEKKIKULAM owned by PRINCIPAL SNIEMS CHEKKIKULAM.....has inspected by me and the sanitary arrangements made at present are satisfactory. Hence a Sanitary fitness certificate issued to run the above thing subject to the condition laid down in the order. Any violation of any one of the conditions will automatically invalid this certificate. I recommend to issue the running licence for the purpose.

This certificate is issued only for the above purpose under the ownership of PRINCIPAL SNIEMS CHEKKIKULAM and personal for during an inspection for the under signed on 25.6.2024

Place: CHEKKIKULAM

Date: 25.6.2024



Health Inspector

[Signature]
HEALTH INSPECTOR